



Product Service

Attestation of Conformity

No. N8 15 08 85780 003

Holder of Certificate: GROUND CO., LTD.950, Deokgeum-ro, Geumwang-eup,
Eumseong-gun, Chungcheongbuk-do 27681
REPUBLIC OF KOREA**Product: Surge protection equipment
(Surge Protective Device)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA01345615**Date,** 2015-09-01
(Hyuk-Jun Kwon)

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8 15 08 85780 003**Model(s):** eca3G LM, eca3G TNC**Parameters:**

Rated input voltage:	255 V a.c.
Rated frequency:	50/60 Hz
Type 2 (Class II test):	65 kA/20 kA
Maximum continuous operating voltage Uc:	275 V a.c.
Voltage protection level Up:	2.5 kV

Tested according to: EN 61643-11:2012